

**TEST REPORT**  
**IEC 61683**  
**Photovoltaic systems –**  
**Power conditioners –**  
**Procedure for measuring efficiency**

**Report Reference No.** ..... : ES160105015S

**Compiled by (name + signature)** ..... : Simon Fan

**Approved by (name + signature)** ..... : William Guo

**Date of issue** ..... : April 05, 2016

**Total number of pages** ..... : 15 pages



**Testing Laboratory name** ..... EMTEK (SHENZHEN) CO., LTD.

**Address** ..... Bldg 69, Majialong Industry Zone, Nanshan District, Shenzhen, Guangdong, China

**Testing location/ address** ..... Same as above

**Applicant's name** ..... Ningbo Ginlong Technologies Co.,Ltd.

**Address** ..... No. 57 Jintong Road, Seafrent(Binhai) Industrial Park, Xiangshan, Ningbo, Zhejiang, 315712,P.R.China

**Test specification:**

**Standard**..... IEC 61683:1999

**Test procedure**..... IEC report

**Non-standard test method**..... : N/A

**Test Report Form No.** ..... IEC61683A

**Test Report Form(s) Originator**..... EMTEK

**Master TRF** ..... Dated 2016-03

**Test item description**..... PV inverter

**Trade Mark**..... N/A

**Manufacturer** ..... Ningbo Ginlong Technologies Co.,Ltd.

No. 57 Jintong Road, Seafrent(Binhai) Industrial Park, Xiangshan, Ningbo, Zhejiang, 315712,P.R.China

**Model/Type reference** ..... Solis-20K, Solis-20K-HV, Solis-25K, Solis-30K, Solis-36K-HV, Solis-40K-HV, URE-20K, URE-20K-HV, URE-25K, URE-30K, URE-36K-HV, URE-40K-HV

**Ratings** ..... See the rating labels.




**Summary of testing:**




The product has been tested according to standard IEC 61683:1999.




**List of Attachments (including a total number of pages in each attachment):**




N/A




<b>Test item particulars</b> .....:	
Equipment mobility.....:	<input type="checkbox"/> movable <input type="checkbox"/> hand-held <input checked="" type="checkbox"/> stationary <input checked="" type="checkbox"/> fixed <input type="checkbox"/> transportable <input type="checkbox"/> for building-in
Connection to the mains.....:	<input type="checkbox"/> pluggable equipment <input type="checkbox"/> direct plug-in <input checked="" type="checkbox"/> permanent connection <input type="checkbox"/> for building-in
Environmental category.....:	<input checked="" type="checkbox"/> outdoor <input type="checkbox"/> indoor unconditional <input type="checkbox"/> indoor conditional
Class of equipment.....:	<input checked="" type="checkbox"/> Class I <input type="checkbox"/> Class II <input type="checkbox"/> Class III <input type="checkbox"/> Not classified
Mass of equipment (kg).....:	N/A
IP protection class.....:	IP65
<b>Possible test case verdicts:</b>	
- test case does not apply to the test object..... : N(/A, Not applicable)	
- test object does meet the requirement..... : P (Pass)	
- test object does not meet the requirement..... : F (Fail)	
<b>Testing</b> ..... :	
Date of receipt of test item..... : January 07, 2016	
Date (s) of performance of tests..... : January 07, 2016 to April 01, 2016	
<b>General remarks:</b>	
<p>"(see Attachment #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>The tests results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced except in full without the written approval of the testing laboratory.</p> <p>List of test equipment must be kept on file and available for review.</p> <p>Additional test data and/or information provided in the attachments to this report.</p> <p>Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</p>	
<b>General product information:</b>	
<p>1. The Solar Inverter converts DC voltage into AC voltage.</p> <p>2. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output. The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.</p> <p>3. All models are identical to model Solis-40K-HV in software and similar in hardware, except different Bus capacitor, type of IGBT and output power which de-rated by software. All tests were performed on the representative model Solis-40K-HV.</p> <p>4. Solis (20-40)K series and URE(20-40)K series are same except for the model number.</p>	
<b>Copy of marking plate:</b>	




 Made in China by Ginlong Technologies	
Model Number	Solis-20K-HV
P <sub>DC</sub> max	23kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3~480Va.c.
F <sub>AC</sub> norm	60Hz
P <sub>AC</sub> norm	20kW
I <sub>AC</sub> max	25Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 4 5 0 1 5 0 6 1 3 9 2
	




 Made in China by Ginlong Technologies	
Model Number	Solis-20K
P <sub>DC</sub> max	23kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3~400Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	20kW
I <sub>AC</sub> max	30.3Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 5 1 0 1 5 0 6 2 3 0 0
	




 Made in China by Ginlong Technologies	
Model Number	Solis-25K
P <sub>DC</sub> max	28.8kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3~400Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	25kW
I <sub>AC</sub> max	37.8Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 3 5 0 1 5 0 4 3 0 7 6
	




 Made in China by Ginlong Technologies	
Model Number	Solis-30K
P <sub>DC</sub> max	34kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3~400Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	30kW
I <sub>AC</sub> max	45.4Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 7 1 0 1 5 0 7 0 4 3 4
	




 Made in China by Ginlong Technologies	
Model Number	Solis-36K-HV
P <sub>DC</sub> max	41.4kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3~480Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	36kW
I <sub>AC</sub> max	47.8Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 8 1 0 1 5 0 5 3 8 5 3
	




 Made in China by Ginlong Technologies	
Model Number	Solis-40K-HV
P <sub>DC</sub> max	45kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3~480Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	40kW
I <sub>AC</sub> max	48.1Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 8 1 0 1 5 0 5 3 8 5 3
	

	
Model Number	URE-25K
P <sub>DC</sub> max	28.8kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3-400Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	25kW
I <sub>AC</sub> max	37.8Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/-2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 3 5 0 1 5 0 4 3 0 7 6
	

	
Model Number	URE-20K
P <sub>DC</sub> max	23kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3-400Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	20kW
I <sub>AC</sub> max	30.3Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/-2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 5 1 0 1 5 0 6 2 3 0 0
	

	
Model Number	URE-30K
P <sub>DC</sub> max	34kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3-400Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	30kW
I <sub>AC</sub> max	45.4Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/-2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 7 1 0 1 5 0 7 0 4 3 4
	

	
Model Number	URE-36K-HV
P <sub>DC</sub> max	41.4kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3-480Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	36kW
I <sub>AC</sub> max	47.8Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/-2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 8 1 0 1 5 0 5 3 8 5 3
	

	
Model Number	URE-40K-HV
P <sub>DC</sub> max	45kW
U <sub>DC</sub> max	1000Vd.c.
I <sub>DC</sub> max (each MPPT)	18A/18A/18A/18Ad.c.
U <sub>DC</sub> startup	350Vd.c.
V <sub>DC</sub> MPPT range	200-800V
V <sub>AC</sub> norm	3-480Va.c.
F <sub>AC</sub> norm	50Hz
P <sub>AC</sub> norm	40kW
I <sub>AC</sub> max	48.1Aa.c.
PF	1
Ambient temperature	-25~60°C
Ingress protection	IP65
Protective class	Class I
Overvoltage category	III(MAINS)II(PV)
Certifications	IEC62109-1/-2, AS3100 VDE 0126-1-1, G59/3 AS4777.2/3, C10/11 RD1699, EN50438
S/N:	 4 8 1 0 1 5 0 5 3 8 5 3
	

IEC 61683			
Clause	Requirement – Test	Result - Remark	Verdict
4	Efficiency measurement conditions		P
	Efficiency shall be measured under the matrix of conditions as described in the following clauses and table 1. Specific conditions may be excluded by mutual agreement when those conditions are outside the manufacturer's allowable operating range. The resulting data shall be presented in tabular form and may also be presented graphically.		P
4.1	DC power source for testing		P
	For power conditioners operating with fixed input voltage, the d.c. power source shall be a storage battery or constant voltage power source to maintain the input voltage.		P
	For power conditioners that employ maximum power point tracking (MPPT) and shunt-type power conditioners, either a photovoltaic array or a photovoltaic array simulator shall be utilized.		P
4.2	Temperature		P
	All measurements are to be made at an ambient temperature of $25\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ . Other ambient temperatures may be allowed by mutual agreement. However, the temperature used must be clearly stated in all documentation.	24 °C	P
4.3	Output voltage and frequency		P
	The output voltage and frequency shall be maintained at the manufacturer's stated nominal values.	3~400Vac/3~480Vac 50Hz	P
4.4	Input voltage		P
	Measurements performed in each of the following tests shall be repeated at three power conditioner input voltages:  a) manufacturer's minimum rated input voltage;  b) the inverter's nominal voltage or the average of its rated input range;  c) 90 % of the inverter's maximum input voltage.	See appended table	P
	In the case where a power conditioner is to be connected with a battery at its input terminals, only the nominal or rated input voltage may be applied.		P
4.5	Ripple and distortion		P



IEC 61683			
Clause	Requirement – Test	Result - Remark	Verdict
	Record input voltage and current ripple for each measurement. Also record output voltage and current distortion (if a.c.) or ripple (if d.c.). Ensure that these measurements remain within the manufacturer's specified values. Note that ripple and distortion may not be specified at low power levels, but readings shall be recorded.		P
4.6	Resistive loads/utility grid		P
	At unity power factor, or at the intrinsic power factor of grid-connected inverters without power factor adjustment, measure the efficiency for power levels of 10 %, 25 %, 50 %, 75 %, 100 % and 120 % of the inverter's rating. Stand-alone inverters shall also be measured at a power level of 5 % of rated. The power conditioner test should be conducted with a specified resistive and reactive grid impedance.	See appended table	P
4.7	Reactive loads		N
	For stand-alone inverters, measure the efficiency with a load which provides a power factor equal to the manufacturer's specified minimum level (or 0,25, whichever is greater) and at power levels of 25 %, 50 % and 100 % of rated VA. Repeat for power factors of 0,5 and 0,75(do not go below the manufacturer's specified minimum PF) and power levels of 25 %, 50 %,and 100 % of rated VA.		N
4.8	Resistive plus non-linear loads		N
	For stand-alone inverters, measure the efficiency with a fixed non-linear load (total harmonic distortion (THD) = $(80 \pm 5) \%$ ) equal to $(25 \pm 5) \%$ of the inverter's rated VA plus sufficient resistive load in parallel to achieve a total load of 25 %, 50 % and 100 % of rated VA. Repeat the measurements with a fixed non-linear load equivalent to $(50 \pm 5) \%$ of the inverter's rated VA plus sufficient resistive load in parallel to achieve a total load of 50 % and 100 %of rated VA. The type of non-linear load must be clearly stated in all documentation.		N
4.9	Complex loads		N
	When a non-linear plus a sufficient reactive load condition is specified for stand-alone inverters, measure the efficiency with a fixed non-linear load (THD = $(80 \pm 5) \%$ ) equal to $(50 \pm 5) \%$ of the inverter's rated VA plus a sufficient reactive load (PF = 0,5) in parallel to achieve a total load of 50 % and 100 % of rated VA. The type of complex load shall be clearly stated in all documentation.		N
5	Efficiency calculations		P

IEC 61683			
Clause	Requirement – Test	Result - Remark	Verdict
5.1	Rated output efficiency	See appended table	P
	Rated output efficiency shall be calculated from measured data as follows: $\eta_R = (P_o / P_i) \times 100$	See appended table	P
5.2	Partial output efficiency		P
	Partial output efficiency shall be calculated from measured data as follows: $\eta_{par} = (P_{op} / P_{ip}) \times 100$	See appended table	P
5.3	Energy efficiency		P
	Energy efficiency shall be calculated from measured data as follows: $\eta_E = (W_o / P_i) \times 100$	See appended table	P
5.4	Efficiency tolerances		P
	When an efficiency value has been guaranteed, the tolerance of this value shall be within the value at rated conditions indicated in table 2.	See appended table	P
6	Efficiency test circuits		N
6.1	Test circuits		N
	Figure 1 shows recommended test circuits for power conditioners which have a single-phase a.c. output or d.c. output. It can as well be regarded as a single-phase representation of a test set-up for multiphase power conditioners.		N
	Figures 1a and 1b shall be applied to stand-alone and utility-interactive power conditioners respectively.		N
	The proposed test circuits in figure 1 are not mandatory, but together with the test descriptions, are intended to establish a base for mutual agreement between user and manufacturer.		N
	The type of power source shall be indicated on all tests and shall adhere to the requirements of 4.1.		N
6.2	Measurement procedure		P
	a) Efficiency is calculated with equation (1) or (2) using measured $P_i$ , $P_o$ or $P_{ip}$ , $P_{op}$ . DC input power $P_i$ , $P_{ip}$ can be measured by wattmeter W1, or determined by multiplying the d.c. voltmeter V1 and d.c. ammeter A1 readings. Output power $P_o$ , $P_{op}$ is measured with wattmeter W2.		P



IEC 61683			
Clause	Requirement – Test	Result - Remark	Verdict
	b) DC input voltage, which is measured by d.c. voltmeter V1, shall be varied in the defined range where the output current, which is measured with a.c. ammeter A2, is varied from low output to the rated output.		P
	c) An average indicating instrument shall be used for the d.c. voltmeter and d.c. ammeter. A true r.m.s. type of indicating instrument shall be used for the a.c. voltmeter and a.c. ammeter. The d.c. wattmeter W1 shall be a d.c. measuring type. The wattmeter W2 shall be an a.c. or d.c. measuring type according to the output.		P
	D )Power factor (PF in per cent) can be measured by a power factor meter PF, or calculated from the readings of V2, A2, W2 and as follows:  $PF = (W_2 / (V_2 \times A_2)) \times 100$		P
	e) Each meter may be an analogue type or a digital type. The measurement accuracy shall be better than $\pm 0,5\%$ of the full-scale value for each power measured. Digital power instruments for W1 and W2 are also recommended.		P
	f) An MPPT dynamically adjusts the input voltage so as to maximize the output power. In principle, the monitoring equipment shall sample all of the electrical parameters, such as input voltage and current, output power and current, within the update period of the MPPT. If the MPPT and input source (PV array or PV array simulator) interact in such a way that the input voltage varies by less than 5 %, then averaging of readings is acceptable. The averaging period shall be 30 s or longer.		P
7	Loss measurement		N
7.1	No-load loss		P
	No-load loss shall be measured as follows.		P
	If the power conditioner is a stand-alone type, the reading of d.c. input voltage, output voltage and frequency is given with meters V1, V2 and F respectively in figure 1a, and shall be adjusted to the rated values.		P
	The no-load loss is thus the indicated value of d.c. input wattmeter, W1, when the load is disconnected from the power conditioner.		P
	If the power conditioner is a utility-interactive type, the reading of d.c. input voltmeter V1, a.c. output voltmeter V2 and frequency meter F in figure 1b shall be adjusted to meet the specified voltages and frequency.		P

IEC 61683			
Clause	Requirement – Test	Result - Remark	Verdict
	No-load loss is thus the indicated value of d.c. input wattmeter, W1, when a.c. wattmeter, W2, indicates a zero value. For the measurement, allow the power conditioner time to transfer to its no-load operating state, if applicable.		P
7.2	Standby loss		N
	Standby loss shall be measured as follows.		N
	If the power conditioner is a utility-interactive type, standby loss is defined as the consumption of utility power when the power conditioner is not operating but is under standby condition. Standby loss is indicated with a.c. wattmeter, W2 in figure 1b at the rated a.c. output voltage.		N
	If the power conditioner is a stand-alone type, standby loss is defined as the consumption from the d.c. source when the power conditioner is not operating but is under standby condition. Standby loss is indicated with d.c. wattmeter, W1 in figure 1a (without a.c. or d.c. output voltage).		N

TABLE: Efficiency									P
Solis-30K									
Input voltage (V)	Total load, % of rated VA		5	10	25	50	75	100	120
manufacturer's minimum rated input voltage 500Vdc	Grid-connected 400Vac	Resistive load	95.96	97.77	98.56	98.61	98.5	98.37	/
the inverter's nominal voltage or the average of its rated input range; 650Vdc	400Vac	Resistive load	95.93	97.59	98.6	98.78	98.69	98.56	/
90 % of the inverter's maximum input voltage 720Vdc	400Vac	Resistive load	95.83	97.77	98.6	98.77	98.73	98.63	/
Solis-25K									
Input voltage (V)	Total load, % of rated VA		5	10	25	50	75	100	120

IEC 61683									
Clause	Requirement – Test	Result - Remark	Verdict						
manufacturer's minimum rated input voltage 500Vdc	Grid-connected 400Vac	Resistive load	95.77	97.66	98.45	98.5	98.39	98.26	/
the inverter's nominal voltage or the average of its rated input range; 650Vdc	400Vac	Resistive load	95.82	97.48	98.49	98.67	98.58	98.45	/
90 % of the inverter's maximum input voltage 720Vdc	400Vac	Resistive load	95.72	97.66	98.49	98.66	98.62	98.52	/
<b>Solis-20K</b>									
Input voltage (V)	Total load, % of rated VA	5	10	25	50	75	100	120	
manufacturer's minimum rated input voltage 500Vdc	Grid-connected 400Vac	Resistive load	95.71	97.6	98.39	98.44	98.33	98.2	/
the inverter's nominal voltage or the average of its rated input range; 650Vdc	400Vac	Resistive load	95.76	97.42	98.43	98.61	98.52	98.39	/
90 % of the inverter's maximum input voltage 720Vdc	400Vac	Resistive load	95.66	97.6	98.43	98.6	98.56	98.46	/
<b>Solis-36K-HV</b>									
Input voltage (V)	Total load, % of rated VA	5	10	25	50	75	100	120	

IEC 61683									
Clause	Requirement – Test				Result - Remark				Verdict
manufacturer's minimum rated input voltage 500Vdc	Grid-connected 480Vac	Resistive load	95.94	97.83	98.62	98.67	98.56	98.43	/
the inverter's nominal voltage or the average of its rated input range; 650Vdc	480Vac	Resistive load	95.99	97.65	98.66	98.84	98.75	98.62	/
90 % of the inverter's maximum input voltage 720Vdc	480Vac	Resistive load	95.89	97.83	98.66	98.83	98.79	98.69	/
Solis-40K-HV									
Input voltage (V)	Total load, % of rated VA		5	10	25	50	75	100	120
manufacturer's minimum rated input voltage 500Vdc	Grid-connected 480Vac	Resistive load	95.81	97.7	98.49	98.54	98.43	98.3	/
the inverter's nominal voltage or the average of its rated input range; 650Vdc	480Vac	Resistive load	95.86	97.52	98.53	98.86	98.72	98.69	/
90 % of the inverter's maximum input voltage 720Vdc	480Vac	Resistive load	95.76	97.7	98.53	98.81	98.76	98.66	/
	Stand-alone	Resistive load	--	--	--	--	--	--	--

IEC 61683									
Clause	Requirement – Test							Result - Remark	Verdict
		Reactive load PF = 0,25 or minimum PF = 0,50 (>minimum) PF = 0,75 (>minimum)	--	--	--	--	--	--	--
		Non-linear load NL = 25 % of rated VA NL = 50 % of rated VA	--	--	--	--	--	--	--
		Complex load	--	--	--	--	--	--	--
Supplementary information:									

Pictures





Pictures

